

## Where Your Money Goes



Your water use charge is \$2.48/100 cubic feet if you are within the City Limits, \$4.96/100 cubic feet if you are outside the City Limits but within 1 mile of the City Limits and \$1.48/100 cubic feet if you are more than 1 mile outside of the City Limits. 65% of this charge is used for operations and maintenance of the water system. 35% of this charge is used for debt retirement.



## Get Involved

We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future. Water conservation measures are an important first step in protecting our water supply. Such measures not only save the supply of our source water, but can also save you money by reducing your water bill. There are a few suggestions:

- Conservation measures you can use inside your home include:
  - ✓ Fix leaking faucets, pipes, toilets, etc.
  - ✓ Replace old fixtures and install water -saving devices in faucets, toilets and appliances.
  - ✓ Wash only full loads of laundry.
  - ✓ Do not use the toilet for trash disposal.
  - ✓ Take shorter showers.
  - ✓ Do not let the water run while shaving or brushing teeth.
  - ✓ Soak dishes before washing.
  - ✓ Run the dishwasher only when full.
- You can conserve outdoors as well:
  - ✓ Water the lawn and garden in the early morning or evening.
  - ✓ Use mulch around plants and shrubs.
  - ✓ Repair leaks in faucets and hoses.
  - ✓ Use water from a bucket to wash your car and save the hose for rinsing.

Information on other ways you can help conserve water can be found on the Environmental Protection Agency's website at [www.epa.gov/safewater/publicoutreach](http://www.epa.gov/safewater/publicoutreach).

### Thirsty for More Information about Your Water?

Please feel free to contact us:

For water sampling and results, water quality complaints, or boil water questions, call:  
 City of Jackson Water Laboratory.....601.960.2723  
 Lenore S. Hicks, Laboratory Supervisor.....601.960.2730

For water leaks or repairs, water meter issues, or locating water lines, call:  
 Water Maintenance (for leaks, repairs, or meters).....601.960.1777  
 601.960.1778

Billing Questions/ Concerns.....601.960.2000  
 For any other non-emergency issue in the City.....311

City of Jackson website.....[www.jacksonms.gov](http://www.jacksonms.gov)  
 MS Dept of Health Bureau of Water Supply.....[www.healthymms.com/watersupply](http://www.healthymms.com/watersupply)



City of Jackson, Mississippi  
 Division of Water/ Sewer Administration  
 200 South President Street  
 P. O. Box 17  
 Jackson, Mississippi 39205-0017

## 2012 Annual Drinking Water Quality Report City of Jackson Maddox Road Well Water System Public Water Supply Identification Number MS0250012 May 29, 2013



We are pleased to present the 2012 Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

You are a valued customer on the City of Jackson Maddox Road Well system. This system is comprised of six (6) groundwater wells located along the Hwy 18 corridor: Wiggins Rd Well, TV Road Well, Maddox Rd Well, Hwy 18 Well, Willowood Well, and Siwell Road Well.

***Our mission is to provide clean, safe drinking water that meets Federal and State regulations, in adequate amounts and at the lowest possible cost.***





## 2012 Water Quality Data

The Mississippi Department of Environmental Quality has completed their source water assessment report which is available for review by appointment at the Water / Sewer Utilities Division Office, 200 S. President Street, Room 405, between the hours of 8:00 AM and 5:00 PM Monday through Friday. Call 601-960-2090 for appointment. The final susceptibility assessment ranking is lower to moderate.

If you have any questions about this report or concerning your water utility, please contact Cynthia Hill, Water Plants Superintendent at 601-960-2417. We want our valued customers to be informed about their water utility. To participate in decisions that may affect the quality of the water, please attend any of our regularly scheduled City Council meetings. They are held every other Tuesday at either 6:00 PM or 10:00 AM within City Hall.

In order to ensure that your tap water is safe to drink, the City of Jackson Maddox Road Well Water System routinely monitors for constituents in your drinking water according to Federal and State laws. These laws limit the amount of certain contaminants in your drinking water. This table shows the results of our monitoring for the period of January 1, 2012 to December 31, 2012.

### Information about Your Water

The sources of drinking water (both tap and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man-made. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage, wildlife, and other sources.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

For more information about contaminants and potential health effects, contact the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.



### The Water Treatment Process

Your water is treated by disinfection. Disinfection involves the addition of chlorine to kill dangerous bacteria and microorganisms that may be in the water. Disinfection is considered to be one of the major public health advances of the 20th century.

City of Jackson Water Plants received a **4.7 out of 5.0** rating from the Mississippi Department of Health for our 2012 Inspection.

TEST RESULTS							
Contaminant	Violation Yes/No	Sample Date	Level Detected	Range of Detects or # of Samples Exceeding AL	MCLG	MCL, TT, AL	Likely Source of Contamination
<b>Inorganic Contaminants</b>							
Barium (ppm)	No	2012	0.0034	0.0020 - 0.0034	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Chromium (ppb)	No	2012	3.95	1.87 - 3.95	100	100	Discharge from steel and pulp mills; erosion of natural deposits
Copper (ppm)* - level from consumer taps; 90th percentile	No	2009	0.2	0 exceeding	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits
Fluoride (ppm)**	No	2012	1.16	0.92 - 1.28	4	4	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Lead (ppb)* - level from consumer taps; 90th percentile	No	2009	2	0 exceeding	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits
<b>Disinfection Byproducts</b>							
Chlorine (ppm)	No	2012	2.2	0.1 - 3.5	4	4	Water additive used to control microbes
Haloacetic Acids (ppb)	Yes	2012	53.0	20.0 - 96.0	N/A	60	Byproduct of drinking water chlorination
Total Trihalomethanes (ppb)	No	2012	55.0	13.2 - 108.0	N/A	80	Byproduct of drinking water chlorination

\*Most recent sample. No sample required for 2012.

\*\*Fluoride level is routinely adjusted to the MS State Department of Health's recommended level of 0.7 - 1.3 mg/L.

(B1) Haloacetic Acids (HAA5). Some people who drink water containing bromate in excess of the MCL over many years have an increased risk of cancer. We routinely monitor for the presence of drinking water contaminants. Testing results we received show that our system exceeded the standard, or maximum contaminant level (MCL) for Disinfection Byproducts in the first three quarters of 2012. The standard for Haloacetic Acids (HAA5) is 0.060 mg/L.

City of Jackson tests its water **MORE THAN 100,000 TIMES A YEAR** to ensure it consistently meets state and federal standards for appearance, quality, and especially safety.

ABBREVIATIONS & DEFINITIONS	
These definitions have been provided to help you better understand the table above.	
<b>Non-Detects (ND):</b> laboratory analysis indicates that the constituent is not present.	<b>Action Level (AL):</b> The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
<b>Parts per million (ppm):</b> one part per million corresponds to one minute in two years or a single penny in \$10,000.	<b>Treatment Technique (TT):</b> A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.
<b>Parts per billion (ppb):</b> one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.	<b>Maximum Contaminant Level (MCL):</b> The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
<b>Picocuries per liter (pCi/L):</b> picocuries per liter is a measure of the radioactivity in water.	<b>Maximum Contaminant Level Goal (MCLG):</b> The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
<b>Millirems per year (mrem/yr):</b> measure of radiation absorbed by the body.	
<b>NTU:</b> Nephelometric Turbidity Unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.	



### For Customers with Special Health Concerns

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

### Additional Information for Lead:

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Jackson is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead and copper testing for \$20 per sample. Please contact 601-576-7582 if you want to have your water tested.



### Fluoridation and Your Drinking Water

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", CITY OF JACKSON is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.7 to 1.3 ppm was 11. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range was 77%.

### Issues in 2012

We are required to monitor your drinking water for the presence of disinfection byproducts (DBPs) on a quarterly basis. During the 2<sup>nd</sup> quarter of 2012, the haloacetic acid Running Annual Average was 62 ppb, exceeding the MCL of 60 ppb. Our customers were promptly notified and corrective actions were immediately taken. Chlorine levels were monitored more closely to ensure compliance the remainder of the 2012 year. In addition, upgrades, improvements, and additions are ongoing that will allow us to supply water from the surface water system (which does NOT have this issue) to the entire city.

### \*April 1, 2013 Message from MSDH Concerning Radiological Sampling\*

In accordance with the Radionuclides Rule, all community public water supplies were required to sample quarterly for radionuclides beginning January 2007 to December 2007. Your public water supply completed sampling by the scheduled deadline; however, during an audit of the Mississippi State Department of Health Radiological Health Laboratory, the Environmental Protection Agency (EPA) suspended analyses and reporting of radiological compliance samples and results until further notice. Although this was not the result of inaction by the public water supply, MSDH was required to issue a violation. This is to notify you that your water system has completed the monitoring requirements and is now in compliance with the Radionuclides Rule. If you have any questions, please contact Karen Walters, Director of Compliance & Enforcement, Bureau of Public Water Supply, at (601)576-7518.